



AMENDMENT 3

**INVITATION FOR BID
UOG IFB No. B25-03**

Date Issued: January 22, 2025

“PURCHASE & INSTALLATION OF CNAS GENERATORS & ATS CABINETS”

This is to notify all prospective offerors of the following amendment set forth below:

1.1 Pre-Bid Conference & Site Visit Minutes set forth as attached

1.2 QUESTION & ANSWER SHEET 2 set forth as attached.

All other terms and conditions remain the same.

Damian Guerrero
Interim Procurement Manager

Please acknowledge receipt and return by email to uog.bids@triton.uog.edu:

Name of company: _____

Print Name/Signature/Date

QUESTION & ANSWER SHEET NO.2

January 22, 2025

*In response to the written "Questions" and/or 'Request for Clarifications' UOG received as of January 21, 2025 @ 9:38 pm from vendor: **GENSET POWER***

Question 1: Please confirm that UOG *is* calling for "enclosure" for the 400kW as specified in the bid?

Answer: UOG: We will accept open type generators as long as it is compatible with the existing ATS Cabinet.

Question 2: Please confirm the replacement of the meter boxes is *not* included in the ATS installation

Answer: UOG: Tentative. Replacements will need to be discussed with administrators, but we will accept the quote on the replacements regardless.

Question 3: Please specify if the ATS is NEMA 1 or NEMA 3R. Please specify if the ATS is *service entranced rated with 200a breaker inside*.

Answer: UOG: ATS is NEMA 3R and is service entranced rated with 200A breaker inside.

Question 4: Please specify items for disposal (i.e., liquids – types of liquids, metal, etc).

Answer: UOG: Disposals will be generators and debris.

**UOG Bid IFB 25-03
Generators & ATS Cabinets
Pre-Bid Conference and Site Visit
Jan. 21, 2025 9:30 a.m.
CNAS**

UOG Representatives:

1. Paul Yamanaka, Ext. Assoc. II, CNAS/CEO
2. Megumi Hikichi, Ext., Assoc. I, CNAS/CEO
3. Damian Guerrero, Property Control Officer, UOG Procurement
4. Jedehiah Danieli, Buyer I, UOG Procurement
5. Bernard Benavente, Resident Inspector, UOG Resident Inspector
6. Francis Bautista, Electrician I, UOG FMS
7. Gregorio Almoite, Building Maintenance Supervisor, UOG FMS
8. Bertha Meno, Maintenance Custodian, UOG FMS
9. Bert Quinata, Refrigeration Mechanic I, UOG FMS

Bid Attendees:

1. Mark Bato, Genset Power
2. Cresente Yilloh, Genset Power

Agenda:

- I. Call to Order: The meeting was called to order by Damian Guerrero at 9:35am.
- II. Announcement by UOG Procurement:
 - a. Site visit will be recorded for documentation purposes (Jedehiah Danieli recorded this meeting).
 - b. Bid Submission: January 28, 2025, on or by 2:00pm
- III. Site Visit:
 - a. ALS Building: Generator & ATS Cabinet was viewed
 - b. Genset Power: Pictures taken by Mark Bato
 - c. House 2: Electrical Panel was viewed
 - d. Paul Yamanaka explained the specifications needed for the other locations
 - e. Yigo Station: Generator & Location of ATS Cabinet was viewed
- IV. Amendments:
 - a. Amendment to follow to state for 1.1:
 - i. ALS Generator must be compatible with existing ATS
 - ii. Accept open generators
 - b. Amendment for 1.5:
 - i. ATS will be NEMA 3R
 - ii. ATS is service entranced rated with 200A breaker inside
 - c. Amendment on all 1.1-1.6:
 - i. Disposal of items: old generators and debris
 - ii. Old Meter box Replacement (Tentative)
- V. Recommendations:
 - a. Yigo Station by Genset Power: Replace Meter at House 2 & Yigo Aquaponics
- VI. Conclusion:
 - a. Damian announced all questions must be submitted in written format to the procurement office. Site visit concluded at 10:45am.

T: +1 671.735.2003

Mailing Address: 303 University Drive UOG Station Mangilao, Guam 96923

The University of Guam is a U.S. Land Grant Institution accredited by the Western Association of Schools and Colleges Senior College and University Commission and is an equal opportunity provider and employer.